

GRATI POWER GENERATOR AND O&M SERVICE UNIT

Tanggal

2026-04-13

NO	PARAMETER	SATUAN	OPERASI (minimal 20 menit)		
			sebelum start	sesudah start	
1	Waktu Pencatatan		09:45	10:10	
2	Oil Pressure	Kg/Cm	6	5	
3	Oil Temperature	C	50	55	
4	Water Temperature	C	45	50	
5	Speed	Rpm	1600	1600	
6	Hour Meter	1	H	109	110
		2	H	-	-
7	Main Line	Voltage	V	400	400
		Frequency	Hz	50	60
8	Generator	Breaker	Open / Close	Open	Open
		Voltage	Hz	50	50
		Frequency	Hz	350	380
9	Load Current	A	0	0	
10	Daya	KW	0	0	
11	COS		1	1	
12	Battery Charge Voltage	V	28	28	
13	Hour	N	506.8	506.9	
14	Lube Oil Level	N	Normal	Normal	
15	Accu Level	N	Normal	Normal	
16	Radiator Level	N	Normal	Normal	
17	Fuel Oil Level	N	Normal	Normal	

Keterangan : L : Low N : Normal H : Hight F : Full

Catatan : start dari lokal

SHIFT

K3

OPERATOR

SUPERVISOR

SHIFT-A			
	Firdaus	Sigit	Dani C