

GRATI POWER GENERATOR AND O&M SERVICE UNIT

Tanggal



2026-04-15

NO	PARAMETER	SATUAN	OPERASI (minimal 20 menit)		
			sebelum start	sesudah start	
1	Waktu Pencatatan		11.05	11.35	
2	Oil Pressure	Bar	7.10	7.18	
3	Fuel Pressure	Bar	1.71	1.74	
4	Fuel Temperature	C	35	35	
5	Coolant Pressure	Bar	2.00	2.03	
6	Coolant Temperature	C	42	42	
7	Speed	Rpm	1502	1502	
8	Inlent Temperature	C	38	38	
9	Turbo Pressure	Bar	1.10	1.10	
10	Generator	Breaker	Open / Close	Open	Open
		Voltage	V	229	230
		Frequency	Hz	50.1	50.1
		Current	A	140	140
11	Load	KW	81	83	
12	Battery Charge Voltage	V	27.8	27.9	
13	Lube Oil Level	N	Normal	Normal	
14	Accu Level	N	Full	Normal	
15	Radiator Level	N	Normal	Normal	
16	Fuel Oil Level	N	Normal	Normal	

Keterangan : L : Low N : Normal H : Hight F : Full

Catatan : start EDG bersama operator dan kru lingkungan pengujian emisi

SHIFT
K3
OPERATOR
SUPERVISOR

SHIFT-B			
	Firsya	Hamdani	Didik H